

Installation Instructions

ET-6C End Termination Kit

Applications

The ET-6C Kit is used for end circuit termination of BSX, RSX, TSX, and VSX self-regulating heating cables.

Kit Contents:

Item	Qty	Description
1	1	End Cap
2	1	RTV Tube

①



②



Tools Required



Warnings

- Due to the risk of electrical shock, arcing and fire caused by product damage or improper usage, installation or maintenance, a ground-fault protection device is required.
- Installation must comply with Thermon requirements (including form PN 50207U for Ex systems) and be installed in accordance with the NEC, CEC, or any other applicable national and local codes.
- Component approvals and performance ratings are based on the use of Thermon specified parts only.
- Keep ends of heating cable and kit components dry before and during installation.

Certifications/Approvals



IP66 NEMA/Type 4X

Ordinary & Hazardous Locations

Listed Heat Tracing Cable System 137M




Certifications vary by cable type. See product specification sheets for additional information.


IECEX




1. Cut off end of cable.



2. Cut and remove overjacket.




3. Trim away exposed braid from cable.



- 4.** Apply a liberal amount of RTV sealant to cable and slide end cap onto the end of the cable.

Cable Take-off for BSX, RSX, TSX, VSX



Thermon Europe B.V.

Boezemweg 25 • 2461 KG Pijnacker • The Netherlands
Phone: +31 (0) 15-36 15370



Thermon Manufacturing Company

100 Thermon Drive • P.O. Box 609 • San Marcos, Texas 78667-0609
Phone: (512) 396-5801 • Fax: (512) 396-3627 • 1-800-820-HEAT
www.thermon.com